



TOWN – VILLAGE OF HARRISON  
**BUREAU OF FIRE PREVENTION**  
One Heineman Place, Harrison, NY 10528  
Phone 914-670-3000 Fax 914-670-3170  
www.harrison-ny.gov



## **APPLICATION FOR FIRE PREVENTION PERMITS** **PERMIT TO INSTALL CARBON DIOXIDE DETECTION SYSTEMS**

THREE SETS OF PLANS AND APPLICABLE FEES MUST BE SUBMITTED WITH ALL APPLICATIONS. FEES ARE NON-REFUNDABLE. CHECK OR MONEY ORDER MADE PAYABLE TO THE TOWN OF HARRISON. **ONE CHECK PER APPLICATION**

APPLICATION NO.: \_\_\_\_\_ DATE FILED: \_\_\_\_\_

### **CHOOSE ONE**

☐ INSTALLATION OF 1-5 DEVICES \$300.00

☐ INSTALLATION OF 6 OR MORE DEVICES \$600.00

PROPERTY ADDRESS \_\_\_\_\_

BLOCK \_\_\_\_\_ LOT(S) \_\_\_\_\_

Description of system to be modified/installed:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

### **Owner**

Name \_\_\_\_\_ Phone \_\_\_\_\_ Fax \_\_\_\_\_

Address \_\_\_\_\_

Email: \_\_\_\_\_

### **Commercial Tenant (if any)**

Name \_\_\_\_\_ Phone \_\_\_\_\_ Fax \_\_\_\_\_

### **Design Professional (must be licensed in the State of New York)**

Name \_\_\_\_\_ Phone \_\_\_\_\_ Fax \_\_\_\_\_

### **Contractor (must be licensed in New York State)**

Name \_\_\_\_\_ Phone \_\_\_\_\_ Fax \_\_\_\_\_

Address \_\_\_\_\_

Email: \_\_\_\_\_ NYS Alarm License # \_\_\_\_\_

### **FOR OFFICE USE ONLY:**

PERMIT FEE \_\_\_\_\_ DATE: \_\_\_\_\_ RECEIPT NO. \_\_\_\_\_

**APPLICANT SIGNATURE:** \_\_\_\_\_ **DATE:** \_\_\_\_\_



TOWN – VILLAGE OF HARRISON  
**BUREAU OF FIRE PREVENTION**  
One Heineman Place, Harrison, NY 10528  
Phone 914-670-3000 Fax 914-670-3170  
[www.harrison-ny.gov](http://www.harrison-ny.gov)



## **APPLICATION FOR FIRE PREVENTION PERMITS** **PERMIT TO INSTALL CARBON DIOXIDE DETECTION SYSTEMS**

### **Application instructions and requirements**

1. Equipment listing, and manufacturer specifications including UL listing or NTRL listing for all equipment being installed must be provided;
2. Floor plan of building showing location of equipment being installed, distributed or stored;
3. Piping design plan indication routing of pipe and method of labeling piping as per ANST A13.1;
4. Construction drawings indicating the entire work proposed, including location of all Carbon Dioxide Sensors with linked alarms and visual signaling devices;
5. All storage, use and handling of Carbon Dioxide shall be in accordance with Chapter 53 of the 2020 Fire Code of New York State and Chapter 13 of NFPA 55;
6. Method of securing cylinders from unauthorized access or accidental dislodgements must be provided;
7. Location of warning signage, required per NFPA 704, and additional hazard warning signage specific to the material is required.